

SERIAL No:

001238

LANDLORD/HOME OWNER GAS SAFETY RECORD

interpart

REGISTERED BUSINESS DETAILS

Reg No: 505651

Company: HALLAMSHIRE ENERGY

Address: 110 PROSPECT RD.

Postcode: S23 5EN

Tel: 08001701889

INSPECTION INSTALLATION ADDRESS

Reg No: —

Company: —

Address: 2A BEECH GROVE.

Postcode: S70 6NG

Tel: —

LANDLORD (OR AGENT) NAME & ADDRESS

Reg No: —

Company: —

Address: Mr D MARTIN.

Postcode: —

Tel: —

Number of appliances tested: 1 ONE

This inspection is for gas safety purposes only to comply with the gas safety (Installation and Use) Regulations. Flues have been inspected visually and checked for satisfactory evacuation of products of combustion. A detailed internal inspection of the flue integrity, construction and lining has NOT been carried out.

APPLIANCE DETAILS							FLUE TESTS				CHIMNEY CHECKS		INSPECTION DETAILS						
	Location	Make Model	Type	Chimney / Flue type OF/RS/FL	Operating pressure in Mbar or heat input kW/h or Btu/h	Safety device(s) correct operation Yes/No/NA	Spillage test Pass/Fail/NA	Smoke pellet flue flow test Pass/Fail/NA	Initial combustion analyser reading	Final combustion analyser reading	Visual condition Satisfactory Yes/No/NA	Chimney/Flue Performance Pass/Fail/NA	Satisfactory termination Yes/No/NA	Flue visual condition Pass/Fail/NA	Adequate ventilation Yes/No	Landlord's appliance Yes/No/NA	Inspected Yes/No	Appliance serviced Yes/No	Appliance safe to use Yes/No
1	Bedroom	Ideal Logic Combi	RS	125	33.6W	Yes	NA	NA	0.002	0.0014	Yes	PASS	Yes	PASS	Yes	Yes	Yes	Yes	Yes
2	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
3	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
4	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/
5	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/	/

Gas Installation Pipework:

Satisfactory Visual Inspection:

Yes ☒ No ☐

Emergency Control Accessible:

Yes ☒ No ☐

Satisfactory Gas Tightness Test:

Yes ☒ No ☐

Equipotential bonding satisfactory:

Yes ☒ No ☐

GIVE DETAILS OF ANY FAULTS

RECTIFICATION WORK CARRIED OUT

WARNING NOTICE ISSUED * Yes/No/NA

WARNING TAG OR STICKER FIXED * Yes/No/NA

Audible CO Alarms:

Approved CO Alarms Fitted:

Yes ☒ No ☐ N/A ☐

Are CO Alarms in Date:

Yes ☒ No ☐ N/A ☐

Testing of CO Alarms Satisfactory:

Yes ☒ No ☐ N/A ☐

Smoke Alarms Fitted:

Yes ☒ No ☐ N/A ☐

OTHER COMMENTS OR OBSERVATIONS

128ppm, 9.1%, 0.0014.

**NEXT
GAS SAFETY
CHECK DUE BEFORE:**

13.3.20

ISSUED BY (GAS ENGINEER)

Print Name: G HARVEY

Signed: [Signature]

Licence No: 478677

Issue Date: 13-7-19

RECEIVED BY

Received By: [Signature]

Tenant/Agent/Landlord/Home Owner

No one present at time of visit ☐

Print Name: F Martin